

QUESTION & ANSWERS

DATE: APRIL 10, 2026

1. Where can we dump the demo material such as native soil, concrete, and asphalt?
 - a. Per the owner's direction during the pre-bid meeting on 4/8/2026, the contractor is to separate the material to be hauled off by material type (ex. Soil, concrete, asphalt) and pile on site. The county (Owner) will then haul the material off site. Most likely, the soil can be deposited somewhere on site.
2. Who will provide the structural fill material under the footings?
 - a. The county will provide the structural fill material and stockpile it on site. The contractor will be responsible to let us know the quantity of fill material needed. The county (Owner) will stockpile the material on site near the building location. The contractor will be responsible to moisture condition the material if required, move and place the material in appropriate lifts, and compact the material per the project requirements.
3. Will the existing power pedestal and water line along the fence near where the new bathroom building stay or go? If it goes, do we need to keep water and power there?
 - a. Per the owner's direction during the pre-bid meeting on 4/8/2026, the existing pedestal is to be removed. The contractor will need to route power and water to ensure the other pedestals and water lines down the fence still have power. This is addressed in Addendum #1.
4. Will the owner provide low-voltage or the contractor?
 - a. Per the owner's direction during the pre-bid meeting on 4/8/2026, the owner will provide what is needed for low voltage. The contractor will need to provide and install underground conduit and a traffic rated ground box for the low voltage. This is addressed in Addendum #1.
5. On page A-602, it shows custodial shelves, is contractor responsible for supplying and installing these shelves per plan?
 - a. Yes, contractor is responsible for supplying and installing the shelves as per the project documents.

Signed:



END OF Q&A

