



2026 STREET STRIPING PROJECT
REQUEST FOR BIDS

ADDENDUM #1

Project Number: IFB-COF-7-26
RFP Issued: April 1, 2026
Addendum #1 Issued: April 10, 2026
RFP Questions Deadline: April 17, 2026 by 2:00 PM
Submission Deadline: May 7, 2026 by 2:30 PM (MST)

This Addendum #1 (the "Addendum 1") is hereby issued to supplement the 2026 Street Striping Project Invitation for Bids (the "IFB") with answers to questions received prior to the deadline. All Offerors must acknowledge receipt of this Addendum 1, and all other and future addenda to the IFB, if any, as part of their respective Bids. This Addendum does not change the deadline to submit a Bid.

Questions and Answers:

Q: I run some rid on line striping machines so I want to make sure this is accepted by the city of Fruita. Also looking into your specs you require the use of water bourn paint with glass beads. 90% of what I do I like to use acrylic, just confirming the city will not allow acrylic.

A: The paint type specified is Federal Specification TT-P 1952 D Type 1 and Type 2. This material is an acrylic waterborne traffic marking paint. Acrylic paint is allowed as long as it meets the specifications in the Project Documents. We would like the line painting to be done with a striping truck. Equipment shall be designed for placement of both solid and broken line stripes with a reasonable clean-edge stripe of the width and location as existing. No overspray on the road surface. Equipment shall have a glass bead dispenser directly behind, synchronized with the paint applicator.

END OF QUESTIONS AND ANSWERS SECTION