



CITY OF FARMINGTON
800 Municipal Drive
Farmington, NM 87401-2663
(505) 599-1373
Fax (505) 599-1377
<http://www.farmingtonnm.gov>

IMMEDIATE ATTENTION

Pneumatic Tube System Request for Information RFI#166677 ADDENDUM TWO (2) APRIL 22, 2026

Notice to Bidders: The above referenced RFI is hereby amended as follows:

The following questions or requests for clarification were received regarding this project. Following each question or request for clarification is the response.

<u>Question</u>	<u>Answer</u>
1 Can you please provide pictures of the existing conditions on the interior and exterior of the building	See Addendum One
2 Details on "new podium" (concrete pour needed? Exact height?)	Concrete podium exists. See pictures. I believe height is between 36 and 44 inches
3 Possible to send pictures of site? Would like to access if infrastructure needs to be replaced, too, or if we can reinstall tubes with existing infrastructure.	See Addendum One
4 What size system would you like us to quote? Most popular is 4", but we also offer 3" and 6", and other specialty sizes.	4"
5 What size is the current system? (diameter)	4"
6 How many terminal boxes inside?	1
7 What is the total length of the system (NEED MEAUREMENTS FOR EACH TERMINAL TO CENTRAL TERMINAL)	Approx 32'
8 How many terminal boxes are outside?	1
9 is there at least 32" of vertical height under the front table/desk? Easiest for our blower to go under the desk inside. terminal will be flush with desk. If there's not room there, we will need to remote the blower from somewhere else (will incur additional material and labour.)	Yes

Receipt of this addendum shall be acknowledged in the Attributes tab in the online bidding system for the above referenced RFI.

If your response has already been submitted, and this addendum will affect your response, please make the appropriate changes to your response in the online bidding system.

Sharon L Tohtsoni
Buyer II
Phone: 505-599-1371
Email: stohtsoni@farmingtonnm.gov

PURCHASING