



Public Works Department
300 Hunt Avenue
Alamosa, CO 81101
Phone: 719.496.7584

**CITY OF ALAMOSA
HUNT AVENUE IMPROVEMENTS PROJECT
CDOT Project # C M015-007 (25245)**

**ADDENDUM #2
5.19.2026**

Item #1

Updated versions of the Project Standard Provisions and the Special Standard Provisions have been uploaded to BidNet & the City's Website

Item #2 Answers to Provided Questions from Potential Bidders

1. Does Davis-Bacon apply to this project?

Davis-Bacon does **not** apply to this project.

2. Does On the job training apply to this project?

On-The-Job-Training (OJT) does **not** apply to this project.

3. I was reviewing the plans and noticed they are calling for epoxy for the sidewalk paint, while everything else is specified as pavement marking paint. Could you provide some clarification on this paint?

The 4-inch wide "rail road rails" are specified as Streetbond SB 120, as noted on plan sheets 44 (shown below) and sheet 49 (Jointing Detail B). This paint shall be paid for by the linear foot under pay item 627-00203 Epoxy Sidewalk Paint (4 Inch Width).

4. Will the City of Alamosa allow ADS HP Storm (corrugated dual wall polypropylene storm pipe) and/or ADS N12 (corrugated dual wall high density polyethylene storm pipe) to be bid as a value engineer alternate to the RCP storm sewer pipe that is specified on the plans?

Yes, the City will allow ADS HP Storm (corrugated dual wall polypropylene storm pipe) and/or ADS N12 (corrugated dual wall high density polyethylene storm pipe) to be bid as a value engineer alternate to the RCP storm sewer pipe that is specified on the plans

5. Will the City of Alamosa allow ADS Nyloplast (PVC drainage structures) to be bid as a value engineer alternate to the concrete inlets that are specified on the plans? Nyloplast is included in Appendix D, number 24, of the City of Alamosa Construction Standards, dated 2022.

Yes, the City will allow ADS Nyloplast (PVC drainage structures) to be bid as a value engineer alternate to the concrete inlets that are specified on the plans?

Attachments:

Updated Project Special Provisions

Updated Standard Special Provisions